

VILLAGE OF WELLSVILLE

WELLSVILLE, OHIO

## AEROBIC DIGESTER CONVERSION PROJECT

### ADDENDUM NO. 1

JULY 8, 2010

All prospective bidders are hereby notified that this addendum forms a part of the contract documents and modifies the original bidding documents dated June 2010. Acknowledge receipt of this addendum in the space provided in the bid proposal section of the specifications. Failure to do so may subject the bidder to disqualification.

#### PREPARED BY:

GGJ, INC.  
35585 Curtis Blvd., Unit C  
Eastlake, Ohio 44095  
(440) 953-1567 (voice)  
(440) 953-0580 (fax)

Please acknowledge receipt by signing below and *faxing back this cover sheet only ASAP* to (440)953-0580.

COMPANY \_\_\_\_\_

NAME \_\_\_\_\_

DATE \_\_\_\_\_

Village of Wellsville  
Aerobic Digester Conversion Project

Addendum #1

July 8, 2010

**Project Specifications:**

General: A Pre- Bid Meeting was conducted on July 7, 2010 @ 10:30 AM at Village Hall. After a brief project description the meeting was relocated to the plant. Attendees at the meeting are as follows:

Bill Boyle, GGJ, Inc.  
James Saracco, Village Administrator  
Andy Pokeivnak, RLM Electric  
Greg Hromiko, WE Downie  
Mike Pusateri, Mike Pusateri Excavating  
Chris Barcus, Cattrell Co. Inc.  
J. Lynn, Wellsville Resident  
Greg Stewart, United Water  
Bruce Bunnell, United Water  
Dave Hort, James White Construction  
Steve George, Synagro

**Section 00300, Bid Proposal Form, Page 1, Item 4**

**DELETE** Entire Item 4, Sludge Dewatering & Disposal  
**ADD** New Item 4, Electrical Allowance Dealing with AEP, Lump Sum \$10,000

A. Measurement: This will be a lump sum amount of \$10,000, to be paid for dealing with AEP on new Electrical Transformers and Metering.

B. Payment: The lump sum stipulated to be paid is for the AEP Cost associated with the new transformers and metering at the Plant. The Contractor will have to provide to the owner an invoice from AEP to verify this cost from AEP for a ready for use installation. The Contact for AEP is Mr. Todd Heaston @ 740-381-7733.

**Page 5, Bid Schedule**

**DELETE** Entire Bid Schedule Sheet  
**ADD** New Bid Schedule Sheet.

**Project Plans:**

**ADD** Drip Edge Detail Sheet, Aerobic Digester Pre-Cast Concrete Plank Topping

**Sheet E-1, Lower Level Electrical Plan**

**DELETE** NEMA 1 Combination Starters  
**ADD** NEMA #SX (Stainless)"Combination Starters and Disconnect Switches".

Note: The Existing underground wiring from the existing power pole to the plants meter is sufficient for the new electrical service.

PROPOSAL TO THE VILLAGE OF WELLSVILLE, OHIO  
AEROBIC DIGESTER CONVERSION


**BID SCHEDULE**

Bid Item	Item Description	Est. Qty.	Unit	Unit Price Material	Unit Price Labor	Total Unit Price	Total Price
1	Bond & Insurance	1	Lump Sum				\$ -
2	Mobilization	1	Lump Sum				\$ -
3	Wastewater Treatment Plant Improvements	1	Lump Sum				\$ -
4	Electrical Allowance Dealing with AEP	1	Lump Sum	\$10,000	-	\$10,000	\$ 10,000.00
<b>TOTAL</b>							\$ -


**TOTAL AMOUNT OF PROJECT (IN FIGURES)** \_\_\_\_\_

**TOTAL AMOUNT OF PROJECT (IN WORDS)** \_\_\_\_\_

END OF SECTION



### ENLARGEMENT



### DRIP EDGE DETAIL

NOT TO SCALE