

VILLAGE OF WELLSVILLE
WELLSVILLE, OHIO

AEROBIC DIGESTER CONVERSION PROJECT

ADDENDUM NO. 2

JULY 12, 2010

All prospective bidders are hereby notified that this addendum forms a part of the contract documents and modifies the original bidding documents dated June 2010. Acknowledge receipt of this addendum in the space provided in the bid proposal section of the specifications. Failure to do so may subject the bidder to disqualification.

PREPARED BY:

GGJ, INC.
35585 Curtis Blvd., Unit C
Eastlake, Ohio 44095
(440) 953-1567 (voice)
(440) 953-0580 (fax)

Please acknowledge receipt by signing below and *faxing back this cover sheet only ASAP* to (440)953-0580.

Project Plans:

Sheet 7 of 8, Door Schedule

DELETE D1; width 3'-0", height 7'-0"
ADD D1; width 5'- 0", height 9'- 4"

Sheet E-1, Electrical Plan

ADD In the area where the existing boiler is to be removed and the new roll up door is to be added, Contractor is to install a new electric roll up door push button operator station and install the wiring on the existing light switch circuit ahead of the light switch.

COMPANY _____

NAME _____

DATE _____