

VILLAGE OF WELLSVILLE

WELLSVILLE, OHIO

SPECIFICATIONS FOR PUMP STATION #1 AND FORCE MAIN IMPROVEMENTS

ADDENDUM NO. 1

SEPTEMBER 27, 2011

All prospective bidders are hereby notified that this addendum forms a part of the contract documents and modifies the original bidding documents dated SEPTEMBER, 2011. Acknowledge receipt of this addendum in the space provided in the bid proposal section of the specifications. Failure to do so may subject the bidder to disqualification.

PREPARED BY:

GGJ, INC.
35585 Curtis Boulevard, Unit C
Eastlake, Ohio 44095
(440) 953-1567 (voice)
(440) 953-0580 (fax)

****THIS ADDENDUM IS BEING TRANSMITTED VIA
FAX ONLY. NO "HARD COPY" WILL BE SENT.****

**Please acknowledge receipt by signing below
and faxing back this cover sheet only ASAP
to (440)953-0580.**

COMPANY _____

NAME _____

DATE _____

CONTRACT SPECIFICATIONS

1. SECTION 00020 (INVITATION TO BID)

REMOVE:

Sealed proposals will be received at the Office of the Mayor, 1200 Main Street, Wellsville, Ohio until 11:00 o'clock A.M. Local Time on **Friday, SEPTEMBER 30, 2011**, or as may be amended by written Addenda, and will be opened and read immediately thereafter for the:

REPLACE:

Sealed proposals will be received at the Office of the Mayor, 1200 Main Street, Wellsville, Ohio until 11:00 o'clock A.M. Local Time on **Friday, OCTOBER 7, 2011**, or as may be amended by written Addenda, and will be opened and read immediately thereafter for the:

GENERAL INFORMATION

Addendum #2 is currently being worked on. Addendum #2 will address the downsizing of the proposed generator from what has been shown on the original contract documents. The revised generator will only accommodate the proposed pump station and not be used for backup of the storm water pump station. These proposed changes to the generator and incidentals will be included in the forthcoming Addendum #2. The Addendum is intended to be issued this Friday September 30, 2011.

Intended changes are not intended to include building size but may include the following;

- Generator
- Transfer switch
- Louvers
- Gas service feed
- Backup power service from proposed building to existing building