

VILLAGE OF WELLSVILLE

WELLSVILLE, OHIO

SPECIFICATIONS FOR PUMP STATION AND FORCE MAIN IMPROVEMENTS

ADDENDUM NO. 1

November 3, 2011

All prospective bidders are hereby notified that this addendum forms a part of the contract documents and modifies the original bidding documents dated SEPTEMBER, 2011. Acknowledge receipt of this addendum in the space provided in the bid proposal section of the specifications. Failure to do so may subject the bidder to disqualification.

PREPARED BY:

GGJ, INC.
35585 Curtis Boulevard, Unit C
Eastlake, Ohio 44095
(440) 953-1567 (voice)
(440) 953-0580 (fax)

****THIS ADDENDUM IS BEING TRANSMITTED VIA
FAX ONLY. NO "HARD COPY" WILL BE SENT.****

**Please acknowledge receipt by signing below
and faxing back this cover sheet only ASAP
to (440)953-0580.**

COMPANY _____

NAME _____

DATE _____

GENERAL COMMENTS AND CLARIFICATIONS

- Bob Boris is the contact at AEP, he can be reached at (330) 382-1473 or rjboris@aep.com
- A disconnect before the meter is a utility company requirement. Please coordinate with Bob Boris as to AEP requirements
- Generator dampers need power. They are fed from circuit #9 in panel PA as shown on drawingE1.
- There have been discussions with AEP regarding moving of overhead feeders and transformer to a new pole and bucking over to another small pole, and then to the proposed building. To date AEP has not issued final drawings or confirmation of which poles are going to be installed and where. This is to be coordinated with Bob Boris.
- Section 03535 shall govern the interior and exterior treatments of the wet well.

GENERAL CHANGES FROM THE ORIGINAL BID

- No acceptable bids were received during the original bid.
- The forcemain has been eliminated from the project (a small section still exists to tie in the new pump station location into the existing force main).
- Plan and profile sheets have been eliminated.
- Mechanical, Electrical, and Plumbing drawings that were updated in Addendum #2 of the original bidding process have been included in the standard drawing set.
- Front end specifications have been adjusted accordingly to accommodate the rebid. Section 00300 Bid Proposal Forms, includes the most significant changes.
- Technical Specifications have been updated to include the relevant sections added in Addendums #2 and #3 of the original bidding process (Sections 16630 and 16635).