

CITY OF CLYDE

CLYDE, OHIO

SPECIFICATIONS FOR WWTP AERATION SYSTEM IMPROVEMENTS

ADDENDUM NO. 1

MARCH 8, 2011

All prospective bidders are hereby notified that this addendum forms a part of the contract documents and modifies the original bidding documents dated FEBRUARY, 2011. Acknowledge receipt of this addendum in the space provided in the bid proposal section of the specifications. Failure to do so may subject the bidder to disqualification.

PREPARED BY:

**GGJ, INC.
35585 Curtis Blvd., Unit C
Eastlake, Ohio 44095
(440) 953-1567 (voice)
(440) 953-0580 (fax)**

****THIS ADDENDUM IS BEING TRANSMITTED VIA
FAX ONLY. NO "HARD COPY" WILL BE SENT.****

**Please acknowledge receipt by signing below
and faxing back this cover sheet only ASAP
to (440)953-0580.**

COMPANY _____

NAME _____

DATE _____

CONTRACT SPECIFICATIONS

SECTION (00020 Invitation to Bid)

1. **Remove:** Each proposal must be made upon the blanks furnished with the Contract Documents and must be delivered to CITY OF CLYDE, 222 N. Main Street, Clyde, Ohio 43410, previous to 10:00 AM, Local Time, on the date specified.

Replace: Each proposal must be made upon the blanks furnished with the Contract Documents and must be delivered to CITY OF CLYDE, 222 N. Main Street, Clyde, Ohio 43410, **PRIOR TO SCHEDULED BID OPENING**, Local Time, on the date specified.

2. **GENERAL:** Bids for the Contract must be sealed and marked CITY OF CLYDE, WWTP AERATION SYSTEM IMPROVEMENT contract number and addressed to the CITY OF CLYDE, 222 N. Main Street, CLYDE, OHIO 43410

Bids submitted as "Limerick Road" will also be accepted.

SECTION (02625 Ductile Iron Pipe and Fittings)

1. **ADD:**

- No Restrained Joints Required
- Push-on and Mechanical Joints Accepted
- Pressure Class 350 pipe
- Stainless Steel Bolts not Required

CONTRACT DRAWINGS

SHEET 1 of 2

1. Project construction limits is located outside of the Preliminary Treatment Building. Replacement of pipe will begin outside of the building. Any work needed to replace the wall pipe, elbow, or vertical rise pipe will be outside the scope of this bid and will be determined in the field.

SHEET 2 of 2

1. Project construction limits is located outside of the Preliminary Treatment Building. Replacement of pipe will begin outside of the building. Any work needed to replace the wall pipe, elbow, or vertical rise pipe will be outside the scope of this bid and will be determined in the field.
2. Centerline pipe EI at Station 0+25 is approximately at 648.17'
Centerline pipe EI at Station 1+80+/- is approximately at 647.83'